

## Safety Signage and Markings Survey & Reports requirement

Site Visit Questions & Answers from 19 November 2015 @0900 event:

The following questions were asked and answered during today's site visit at Naval Base Coronado:

1. What is the expected level of effort to identify container labeling (primary and secondary) as part of the hazard communication standard? Do you want an inspection of all containers (chemical inventory)?
  - a. A HAZMAT inventory is not part of this project; however, the contractor is encouraged to exam a sample of labels as pertinent to general signage requirements.
2. Should markings/labeling include piping?
  - a. No.
3. Will this project capture labeling of hazardous energy sources/LOTO/disconnects?
  - a. Yes.
4. What are you looking for regarding emphasis?
  - a. Report for each of the 18 buildings identified in the Statement of Work to survey & assess current building standards as compliant with 29 CFR 1910 OSHA regulations. The report should provide an in-depth analysis regarding appropriate sign Hazardous OSHA compliant requirements to be posted.
5. What type of contract will be awarded?
  - a. Firm-Fixed Price contract will be awarded.
6. How would you want signs developed?
  - a. This requirement does not require the contractor to develop HAZMAT signs for safety. The deliverables include a report by building site with all current appropriate signs in hazardous work areas related to safety concerns.
7. Are vendors creating signs or reports for this requirement?
  - a. Only reports for each building identified on the SOW which includes an evaluation of survey data, sampling reports, recommendations, suggestions all in compliance with 29 CFR 1910 OSHA standards.